



Application Note AN-NIR-096

Water in diesel with NIRS

Moisture in diesel fuel within seconds using NIR spectroscopy

Fuels can incorporate traces of water during the production process, in transport, and while in storage. Excessive water in fuels leads to several problems. For example, elevated water content in diesel fuel promotes biological growth in storage fuel tanks, which could lead to metal corrosion and formation of sludge and biofilms. This in turn clogs filters in fuel systems and results in damage to diesel engines.

The standard specification for diesel fuel quality includes multiple parameters, but dissolved water is the biggest risk factor. According to the European

Committee for Standardization, the maximum acceptable amount of water in diesel fuel for commercialization is 200 mg/L (ppm) (EN 590). Usually, this is determined by Karl Fischer (KF) titration, yet this method requires chemicals and takes about five minutes to perform. This Application Note describes how near-infrared spectroscopy (NIRS) is a faster and more cost-efficient alternative to KF titration for the **prediction of water content** in diesel fuel.

EXPERIMENTAL EQUIPMENT

Samples of diesel with varying water content (from 66 to 362 mg/L) were measured with an OMNIS NIR Analyzer Liquid in transmission mode (1000–2250 nm). Reproducible spectrum acquisition was achieved using the built-in temperature control. For convenience, disposable vials with a pathlength of 8 mm were used, which made cleaning of the sample vessels unnecessary. The OMNIS software was used for all data acquisition and prediction model development.



Figure 1. OMNIS NIR Analyzer and a sample filled in a disposable vial.

Table 1. Hardware and software equipment overview.

Equipment	Article number
OMNIS NIR Analyzer Liquid	2.1070.0010
Holder OMNIS NIR, vial, 8 mm	6.07401.070
Disposable vial, 8 mm, transmission	6.7402.240
OMNIS Stand-Alone license	6.06003.010
Quant Development software license	6.06008.002

RESULT

The NIR spectra (**Figure 2**), along with the corresponding reference values, were used to create a prediction model for quantification of the moisture content in diesel samples. The quality of the prediction model was evaluated using the correlation diagram shown in **Figure 3** which displays a very high

correlation between the NIR prediction and the measured values of water content using KF titration (reference values). The respective figures of merit (FOM) display the expected precision of a prediction during routine analysis.



Figure 2. Stacked collection of NIR spectra from diesel samples analyzed with the OMNIS NIR Analyzer Liquid.



Figure 3. Correlation diagram and the respective figures of merit for the prediction of water content in diesel using an OMNIS NIR Analyzer Liquid. The lab values were evaluated using KF titration.

R^2	SEC (mg/L)	SECV (mg/L)
0.957	12	17

This Application Note demonstrates the feasibility to determine a key parameter for the quality control of diesel fuel – water content – with NIR spectroscopy. The main advantages of NIR spectroscopy over wet chemical methods like KF titration are that running

costs are significantly lower and time-to-result is significantly reduced to a few seconds. Additionally, no chemicals are required, and the technique is non-destructive to samples.

Table 2. Time to result overview for KF titration.

Parameter	Method	Time to result
Water	Karl Fischer titration	5 minutes

Internal reference: AW NIR CH-0064-112021

CONTACT

Metrohm RUS
ул. Корабельная 9А,
помещ. 5/1
115142 Москва

info@metrohm.ru